



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO - ws/lab/320/2024

Date - 18/07/2024

To
The Principal,
Sterling School,
Bhosari.

Subject: Water sample Potability Certificate.


Drinking water sample provided by Sterling School, Bhosari on Date: 10/07/2024 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /302/2024 dated 10/07/2024 & ws /lab /303/2024 dated 11/07/2024 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.


Chief Chemist
Pimpri Chinchwad Municipal Corporation
Pimpri -18

INWARD
S No STA/136/24-25
Date . 19/7/2024


29/07/2024

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 302 / 2024

DATE - 10/07/2024

DATE OF RECEIPT - 10/07/2024

DATE OF EXAMINATION - 10/07/2024

NAME - Sterling School

ADDRESS - Bhosari

SOURCE Pune water

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	0.87 NTU		
2	ph	6.5 to 8.5	7.74		
3	Total Hardness (as CaCO ₃)	200 mg/lit	88 mg/l		
4	Chloride	250 mg/lit	30 mg/l		
5	Calcium	75 mg/lit	24.04 mg/l		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

Water Treatment Plant
Sector 23 Nigdi

INWARD

S No. STA/136/24-25

Date: 19/7/24

18/07/2024